



**CERTIFICATION TO DISCHARGE UNDER CDPS GENERAL PERMIT COG070000  
 CONSTRUCTION DEWATERING DISCHARGES**

Certification Number: **COG076964**  
 This Certification to Discharge specifically authorizes:  
**TDA Construction Inc**  
 to discharge from the facility identified as

**Meeker Circle Park  
 to: White River**

**Facility Located at:** 20 5th Street Meeker, CO 81641, Rio Blanco County  
 Center Point Latitude 40.033745 Longitude -107.911123

Undefined Discharge Outfall(s) to Surface Water	Discharge Outfall(s) Description*
Outfall Number 001-AU	<p>The permit certification authorizes <b>one</b> discharge outfall to surface water from a specific location within the project boundary (as defined in the permit application). The location for the outfall is defined and established by the permittee prior to the discharge commencing. The <u>outfall location</u> shall not be changed once established.</p> <p>The dewatering effluent will be discharged to an irrigation ditch with flow to the White River. Monitoring shall occur after the implementation of any best management practices and prior to discharge to the irrigation ditch.</p>

\*All discharges must comply with the lawful requirements of federal agencies, municipalities, counties, drainage districts and other local agencies regarding any discharges to storm drain systems, conveyances, or other water courses under their jurisdiction.

**Permit Limitations and Monitoring Requirements apply to 001-AU as outlined in the Permit Part I.B and Part I.C**

Parameter	Units	Discharge Limitations Maximum Concentrations			Monitoring Frequency	Sample Type
		30-Day Average	7-Day Average	Daily Max.		
<b>APPLICABLE TO ALL DISCHARGES AS LISTED IN GENERAL PERMIT</b>						
pH, (Minimum-Maximum) 00400	s.u.	NA	NA	6.5-9.0	Weekly	In-situ
Total Suspended Solids 00530	mg/l	30	45	NA	Weekly	Grab
Flow <sup>1</sup> 50050	gpm	NA	NA	100	Weekly	Instantaneous or Continuous
Oil and Grease Visual 84066		NA	NA	NA	Weekly	Visual <sup>2</sup>
Oil and Grease 03582	mg/l	NA	NA	10	Weekly	Grab <sup>2</sup>
<b>SITE SPECIFIC PARAMETERS</b>						
Total Dissolved Solids 70295	mg/l	Report	NA	Report	Monthly	Grab

<sup>1</sup> The maximum flow limit will be equal to twice the maximum flow rate provided in the permit application or subsequent modifications.

<sup>2</sup> If a visible sheen is observed, a grab sample shall be collected and analyzed for oil and grease.



**Certification is issued and effective: 5/18/2020**

**Expiration Date:** This authorization expires upon effective date of the General Permit COG070000 renewal unless otherwise notified by the division.

ADMINISTRATIVELY CONTINUED

This certification under the permit requires that specific actions be performed at designated times. The certification holder is legally obligated to comply with all terms and conditions of the permit.

This certification was approved by:  
Margo Griffin, Unit 1 Work Group Lead  
Permits Section  
Water Quality Control Division

